

Mr Malcolm Moss
Managing Director
Doby Verrolec
Harelaw Industrial Estate
Stanley
Co. Durham
DH9 8UJ

25 February 2008

Dear Malcolm


Re: New Corner Pieces for Doby/Xcel Flange System

Thank you for your letter of 17 December 2007 regarding the new corner pieces for the Doby/Xcel Flange System in which you detail the corners construction.

I passed on the information to Jim Murray, Chairman of the Ductwork Group Technical Committee, who reviewed your technical data and your testing procedures in accordance with DW/144 and DW/TM1. Both Jim and the HVCA are confident that Doby's new corner pieces are fully compliant with DW/TM1 and I am therefore pleased to report that the association has no problem in accepting the Doby Verrolec proposals for the minor modifications to the corner pieces.

Details of the new corner pieces will be placed on the DW/TM1 database and a copy of all correspondence will be kept in our records for reference.

Kind regards



Mark Oakes
Group Services Officer

e: moakes@hvca.org
t: 020 7313 4935